

AM/BJ.




هيئة كهرباء ومياه دبي
Dubai Electricity & Water Authority



PO #: 3761400101
Ref #: MAT-ELE-007
Rev#: 1
Date: 29-June-2017

APPROVAL OF MATERIAL

Project Name: Construction of 33/11 kV Substation at Tawi Lehabab-11



Plot No. 8319767

Location: Tawi lehabab-11

Department

Architectural

Structural

MTP

Material(s) Item: Light Fixture

Client Specified Material(s)

Alternative

Elmark

Supplier of Material(s)

M/s. Masons

Manufacturer

M/s. Elmark

Enclosures

1 No. of submittal

Reason(s) for Alternative Applier / Installer



Sample is ready for inspection on

NA

At

NA

Submitted By

Rajeev. S

Signature

Date

29.06.2017

This portion is for the use of Consultant only

Status

Approved

Approved As Noted

Rejected

Resubmit

Comments:

Signed by

Signature

Date

This portion is for the use of Client only

Status

Approved

Approved As Noted

Rejected

Resubmit

Comments:

Approved Subject to achieving the specified lux levels at site. Any shortfall in illumination level at site shall be increased by adding additional fixture or re-arrangement without any additional cost & time to the client.

Signed by

Signature

Date

29/6/17
29/6/17

3 Years Warranty Certificate shall be Submitted.